

EO1-SAA098S05-011  
SHEET 3 OF 8SA098S05-011  
REV.A

OCT 10 1980

SD0C244  
ATTACHMENT -  
Page 56 of 52CRITICAL ITEM: HEPA Filters (two assemblies, two filters in each assembly)Find Number: A143076, A143075      System: VPF Payload ECSFailure Category: 2      SMN No.: 098S05-011NASA Part No.: None      PNM/Name: S72-1257Mfr's Flanders Filters,  
Part No.: Inc. 007-C-08-03-1E-YYF      Drawing/ E1116 8 Watts  
Sheet No.: 353J5; 79K22629Function: Filters particles from conditioned airCritical Failure Mode: Pass contaminants (PNM 098S05-011.002)Cause: Failure of filter media or leakage around gasketFailure Effect: Particulate contamination of payloadACCEPTANCE RATIONALE:Design:

- o Filter medium and efficiency: nonwoven glass paper (boron-aluminate microfiber), 99.97% minimum efficiency on 0.3 micron particles.
- o Separator material: flat sheet, pleated over 0.0015" (minimum thickness) corrugated-aluminum separators with hemmed edges.
- o Frame material: 14-gauge, galvanized steel.
- o Frame style: double turn flanges both faces, neoprene gaskets.
- o Sealant: high-temperature silicone (8004 F/2604 C - supply air)
- o Size 23 1/8" x 23 3/8" x 11 1/2" (H x W x D)
- o The capacity of each filter is 1138 C.F.M. at 1.00" H<sub>2</sub>O pressure drop. There are two filters in each assembly, for a total capacity of 2270 C.F.M. at 1.00" H<sub>2</sub>O pressure drop. The vendor manual states that each air circuit supplies 150 lbs./min. of conditioned air, which is equivalent to 1984 C.F.M. at 55° F. The unit is normally used below full capacity.

Test:

File VI CM850, as implemented by GMZ C9501, requires verification of particulate count and hydrocarbon content prior to initial connection to the payload and verification of satisfactory temperature, humidity, pressure and flow before and during use.

Inspection:

- o After start-up of the ECS, a sample of air from an outlet discharge is tested with a particle counter. The air's cleanliness level is checked to verify that it is class 5000 per Federal Standard 209.
- o The differential pressure across the filter is measured and shown on a gage.

EO1-SAA096S05-011  
SHEET 6 OF 8SAA096S05-011  
REV.A

OCT 10 1990

SO40246  
ATTACHMENT  
Page 57 of 68

- o The pressure gages are calibrated annually.
- o During quarterly maintenance, it is verified that the HEPA filter differential pressure gage readings are within the 0-1.5 inches H<sub>2</sub>O range.

Failure History:

From 1981 to the present, no PRACA reports were written on HEPA filters in this system.

Operational Use:

This system is used in accordance with QNI E3501. Out of tolerance readings will result in termination of payload testing.

X - 940

OCT 25 '90 10:12