

Critical Item: 8 Channel Analog Measurement Card

JUN 10 1997

Find Number: 78K00459 11 ea.

Criticality Category: 1S

SYSTEM	AREA	CRIT	TOTAL LRU'S
Hypergol Vapor Detection Sys	LOA	1S	11

SAA No:	09IT09-001	System/Area:	LPS/CCMS/FR1/FR2/CR3/CR4
NASA Part No:	78K00459/78K02459	PMN/ Name:	L72-0400-03 HIM
Mfg/ Part No:	78K00459/78K02459	Drawing/ Sheet No:	MCR7656 VOL. III 4.2 (REV. CY)

**Function:** This HIM Critical Item is used in support of a critical user system. It accepts an analog current or voltage input signal from user GSE and converts it to 8 bit digital data for shipment to FEP.

**Critical Failure Mode/Failure Mode No:** \* Failure Mode - Unsolicited Operation/09IT09-001.489

\* 8 channel analog measurement card failures could cause erroneous data readings or affect normal HIM I/O bus communication resulting in loss of the data path for the critical system being monitored/controlled.

**Failure Cause:** Electrical/Electronic failure of LRU piece part

**Failure Effect:**

SYSTEM	FAILURE EFFECT	CRIT
Hypergol Vapor Detection System (LOA)	Loss of output signal will fail to provide the console operator with an input that would indicate a leak in the hypergol propellant servicing system. Loss of the capability to detect a leak during hazardous operations could result in loss of life and/or vehicle. Time to effect: Immediate. Detection method: Software detects loss of HIM functions.	1S

8 Channel Analog Measurement Card (Continued)

JUN 10 1997

## ACCEPTANCE RATIONALE

**Design:** The 8 Channel Analog Measurement Card was designed per the requirements of the following documents.

1. CP09IT0910: General design requirements specification for LPS/CCMS.
2. CP09IT0914: Contract end item assembly specifications for CDBFR for LPS/CCMS.

These specifications support the Shuttle design and procurement philosophy procurement of hardware that is not undergoing development, but to procure "off-the-shelf hardware" and to maximum extent possible parts previously qualified through proven design.

**Test:** Rigorous sets of acceptance tests were performed to verify performance and design requirements of the LPS/CCMS. This process occurred on each end item from "In Process Assembly" phase to "Site Acceptance". Master control procedures (MCPs) 78K-M401 and 78K-M701 were utilized for acceptance testing by MMC. Following this acceptance testing IBM performed integrated testing of each set. Test procedures KSC-LPS-IB-086, Book 3 and KSC-LPS-IB-105, Book 5 were utilized.

### Hypergol Vapor Detection Sys

- OMRSD File VI Volume 1 requires a sensor functional test prior to each flow. OMI V3542 "Hypergol Vapor Detection System Operations Support (LPS)" provides this end-to-end verification of the system (LPS/HVDS).
- During loading operations, personnel are stationed on the RSS to provide visual monitor.

**Inspection:** LPS system integrity is continuously monitored by on-line software programs. These programs provide health and status to system operators. OMRSD, File VI requires verification of backup power to be performed every 360 days on the hardware interface module which contains this LRU. OMI C6040 "HIM Preventive Maintenance" satisfies this requirement. Proper HIM operation is verified by each user system as part of the end-to-end verification of their integrated system.

### Failure History:

The PRACA Data Base was used for this analyses (time frame APR. 88 to Sep. 90). There were 30 Problem Reports initiated on 8 Channel Analog Measurement Cards that relate to failure modes depicted on this CIL sheet. There is a total population of 784 8 Channel Analog Measurement Cards installed in various CCMS Station Sets. In the basic SAA the timeframe of Jan. 84 to Mar. 88 was used with 380 Problem Reports identified from a total population of 1028 cards installed. Operation use varies from 7 days a week, 24 hours a day to as required.

JUN 10 1997

8 Channel Analog Measurement Card (Continued)

**Operational Use:**

- **Correcting Action:**  
Troubleshooting required to isolate and replace failed unit.
- **Timeframe:**  
Varies, troubleshooting required.