

USA Ground Operations CIL Sheet

AUG 23 1999

Critical Item: Valve, Solenoid

Criticality Category: 1S

NASA Part No: None

Total Quantity: 9

Mfg/Part No: ASCO / HT8344G82-24VDC

System: Facility Water System

Find No.	Qty	Area	PMN	Baseline	Drawing / Sheet
A154668 (SV-75)	1	Pad-A	K60-0060	007.00	79K06011 / 24
A154672 (SV-76)	1	Pad-A	K60-0060	007.00	79K06011 / 24
A154697 (SV-77)	1	Pad-A	K60-0060	007.00	79K06011 / 24
A154701 (SV-78)	1	Pad-A	K60-0060	007.00	79K06011 / 24
A154738 (SV-107)	1	Pad-A	K60-0060	007.00	79K06011 / 23
A154742 (SV-108)	1	Pad-A	K60-0060	007.00	79K06011 / 23
A156565 (SV-110)	1	Pad-A	K60-0060	007.00	79K06011 / 25
A156575 (SV-111)	1	Pad-A	K60-0060	007.00	79K06011 / 25
A157157 (SV-116)	1	Pad-A	K60-0060	007.00	79K06011 / 25

Function:

Controls air supply to associated flow control valve to pressurize open side of the actuator for the associated water control valve and provides a capability to vent the close side of the actuator for the associated water control valve.

Failure Mode No. Failure Mode	Failure Cause Failure Effect	Detection Method Time to Effect	Crit Cat
09SY03A-001.010 Fail closed	Binding, corrosion, contamination, or failure of internal piece part Loss of capability to pressurize open side of actuator on associated water control valve and allow fire/deluge water flow to the associated area. Possible loss of life and/or vehicle during a hazardous condition.	Water valve position switch Immediate	1S

ACCEPTANCE RATIONALE

Design:

- Rated working pressure 125 psid.
- Actual working pressure is 125 psid.

Test:

- OMI M2067 requires cycling of FSS/RSS water valves to verify proper operation.
- OMRSD, File VI requires verification of the operational function of the water valves in all modes of operation semiannually (service structure), annually (perimeter area), and at replacement. (Note: Water valve operational function verification ensures valve opens within design opening rate which also verifies solenoid valve has not failed.)

Inspection:

- OMI 6045 requires the inspection of the fire valves for signs of corrosion and/or contamination.

Failure History:

- Current data on test failures, unexplained anomalies, and other failures experienced during ground processing activities can be found in the PRACA database. The PRACA database was researched and no

USA Ground Operations CIL Sheet AUG 23 1999

failure data was found on this component in the critical failure mode.

- The GIDEP failure data interchange was researched and no failure data was found on this component in the critical failure mode.

Operational Use:

Correcting Action	Timeframe
There is no action which can be taken to mitigate the failure effect.	Since no correcting action is available, timeframe does not apply.